


CONTROLLED



Note: Add unit foot and lifting lug

DESIGN DATA	
DESIGN PRESSURE	3.0Mpa
TEST PRESSURE	4.5MPa
DESIGN TEMPERATURE	-196/+225
LEAKAGE TEST	Helium Test
PLATE MATERIAL	316L
PIPE MATERIAL	304
FRAME MATERIAL	304

ID	RIDAN Code	Drawing No.	Model	Plates(n)	A	WEIGHT	VOLUME
1	021H4721R	2306591	210	140	373	116Kg	H1H2:35L/Q3Q6:34.5L

Assembly drawing	DEPARTMENT	Sales	DATE	SCALE			
	DESIGNER	JLN	2022/06/26				
	INSPECTOR	ZJF	2022/06/26				
APPROVAL	FL	2022/06/26					
DRAWING NO.						2306591	REV 0

DESIGNATION RD-210-140-3.0-HQ-H1H2(L3)/Q3(H1"5/8)/Q6(H3"1/8)/12-M10\*25

Version	Change date	Description	State	Designer
1	2022/06/28	H1H2 change from NPT3" to G 3"(BSPP)	①	JLN